

UL-EU CERTIFICATE

Certificate No. UL-EU-01049-CPR
Page 1/8
Date of Issue 2017-07-26
Revised 2017-09-26

Certificate Holder PROMAT FIRE PROTECTION LLC
Plot No. 597-921
Dubai Investment Park 2
PO Box 123945
Dubai
United Arab Emirates

Manufacturer A/013

Certified Product Type Fire Stop – Pipe Collar
Product Trade Name PROMASTOP®-COLLAR
Trademark N/A
Rating/Classification See Appendix

Harmonised Technical Specifications ETAG 026-2 / EN 13501-2 / EN 13501-1
Supporting Documentation ETA 15/0489, EC – CERTIFICATE OF CONSTANCY OF PERFORMANCE - 1121 – CPR – JA5080
Additional information N/A
Expiry date 2027-07-25



A handwritten signature in purple ink, appearing to read 'Chris Miles', is written over a horizontal line.

Head of Notified Body
Chris Miles

This is to certify that representative samples of the Certified Product listed above have been investigated by Underwriters Laboratories to the Standard(s) indicated on this Certificate, in accordance with the UL Global Services Agreement and the UL-EU Mark Service Terms and Conditions ("Agreement"). The Certificate Holder is entitled to use the UL-EU Mark for the Certified Product listed on the certificate and manufactured at the production site(s) listed, in accordance with the terms of the Agreement. Only those products bearing the UL-EU Mark for Europe should be considered as being covered by UL's UL-EU Mark Service. This Certificate shall remain valid through the Expiration date, unless a Standard identified on this Certificate is amended or withdrawn prior to that date or there is a non-compliance with the Agreement.



Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-01049-CPR
Page 2/8
Date of Issue 2017-07-26

This certificate relates to the use of PROMASTOP®-COLLAR for fire stopping where services penetrate floors and walls. The detailed scope is given in pages 3 to 5 of this Certificate. This shows the thickness and acceptable dimensions, substrates and orientations required to provide fire resistance periods of up to 240 minutes (EI 240).

The product is certificated on the basis of:

- i) ETA 15/0489
- ii) EC – CERTIFICATE OF CONSTANCY OF PERFORMANCE 1121 – CPR – JA5080
- iii) Inspection and surveillance of factory production control by UL
- iv) Fire resistance test data in accordance with 1366-3: 2009
- v) Classification in accordance with EN 13501-2
- vi) Classification in accordance with EN 13501-1
- vi) Durability and Servicability as defined in ETAG 026-2

The durability class of PROMASTOP®-COLLAR is X - intended for use in conditions exposed to weathering (includes all lower classes).



Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-01049-CPR
 Page 3/8
 Date of Issue 2017-07-26

Product-type: Pipe Collar		Intended use: Penetration Seal
Basic requirement for construction work	Basic Requirement	Basic requirement for construction work
BWR 1 Mechanical resistance and stability		
-	None	-
BWR 2 Safety in case of fire		
EN 13501-1	Reaction to fire	Class E
EN 13501-2	Resistance to fire	See page 5
BWR 3 Hygiene, health and environment		
EN 1026:2000	Air permeability (material property)	No performance determined
ETAG 026-3, Annex C	Water permeability (material property)	No performance determined
Declaration of manufacturer	Release of dangerous substances	Use category IA1, S/W3 Declaration of manufacturer
BWR 4 Safety in use		
EOTA TR 001:2003	Mechanical resistance and stability	No performance determined
EOTA TR 001:2003	Resistance to impact/movement	No performance determined
EOTA TR 001:2003 ISO 11600	Adhesion	No performance determined
BWR 5 Protection against noise		
EN 10140-2/ EN ISO 717-1	Airborne sound insulation	No performance determined
EN 10140-3/ EN ISO 717-2	Impact sound insulation	No performance determined
BWR 6 Energy economy and heat retention		
EN 12664, EN 12667 or EN 12939	Thermal properties	No performance determined
EN ISO 12572 EN 12086	Water vapour permeability	No performance determined
General aspects relating to fitness for use		
ISO 8339: 2005, ISO 9046: 2004 & ISO 7389: 2003	Durability and serviceability	X
BWR 7 Sustainable use of natural resources		
-	-	No performance determined



Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-01049-CPR
 Page 4/8
 Date of Issue 2017-07-26

Substrate	Minimum Substrate Thickness (mm)	Annular space sealed with PROMASEAL® Acrylic Sealant (mm)	Collar Position	Inlay W X H (mm)	Reference	Pipe	Fire Resistance (mins.)	
							E	EI
Drywall/ Masonry/ Concrete wall	100	10	Both sides	30 x 4	32 mm PROMASTOP®- COLLAR	32 mm Ø PVC with 1.8mm wall thickness	120*	120*
					40 mm PROMASTOP®- COLLAR	40 mm Ø PVC with 1.8mm wall thickness		
					50 mm PROMASTOP®- COLLAR	50 mm Ø PVC with 1.8mm wall thickness		
				30 x 6	55 mm PROMASTOP®- COLLAR	55mm Ø PVC with 2.3-3mm wall thickness		
					63 mm PROMASTOP®- COLLAR	63mm Ø PVC with 2.3-3mm wall thickness		
				30 x 8	75 mm PROMASTOP®- COLLAR	75mm Ø PVC with 3.1-4.8mm wall thickness		
					82 mm PROMASTOP®- COLLAR	82mm Ø PVC with 3.1-4.8mm wall thickness		
				30 x 10	90 mm PROMASTOP®- COLLAR	90mm Ø PVC with 4.2-7.4mm wall thickness		
					100 mm PROMASTOP®- COLLAR	100mm Ø PVC with 4.2-7.4mm wall thickness		
					110 mm PROMASTOP®- COLLAR	110mm Ø PVC with 4.2-7.4mm wall thickness		
				40 x 12	125 mm PROMASTOP®- COLLAR	125mm Ø PVC with 6.0mm wall thickness		
				40 x 16	140 mm PROMASTOP®- COLLAR	140mm Ø PVC with 6.1-7.5mm wall thickness		
				40 x 18	160 mm PROMASTOP®- COLLAR	160mm Ø PVC with 6.2-9.5mm wall thickness		
				30 x 4	32 mm PROMASTOP®- COLLAR	32 mm Ø PP with 2.9mm wall thickness		
					40 mm PROMASTOP®- COLLAR	40 mm Ø PP with 2.9mm wall thickness		
					50 mm PROMASTOP®- COLLAR	50 mm Ø PP with 2.9mm wall thickness		
				30 x 6	55 mm PROMASTOP®- COLLAR	55mm Ø PP with 2.9-4.4mm wall thickness		
					63 mm PROMASTOP®- COLLAR	63mm Ø PP with 2.9-4.4mm wall thickness		
				30 x 8	75 mm PROMASTOP®- COLLAR	75mm Ø PP with 2.8-6.7mm wall thickness		
					82 mm PROMASTOP®- COLLAR	82mm Ø PP with 2.8-6.7mm wall thickness		
				30 x 10	90 mm PROMASTOP®- COLLAR	90mm Ø PP with 2.7-10mm wall thickness		
					100 mm PROMASTOP®- COLLAR	100mm Ø PP with 2.7-10mm wall thickness		
					110 mm PROMASTOP®- COLLAR	110mm Ø PP with 2.7-10mm wall thickness		
				40 x 12	125 mm PROMASTOP®- COLLAR	125mm Ø PP with 3.1mm wall thickness		

* Uncapped/Capped (U/C)
 ~Uncapped/Uncapped (U/U)



Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-01049-CPR
 Page 5/8
 Date of Issue 2017-07-26

Substrate	Minimum Substrate Thickness (mm)	Annular space sealed with PROMASEAL® Acrylic Sealant (mm)	Collar Position	Inlay W X H (mm)	Reference	Pipe	Fire Resistance (mins.)	
							E	EI
Drywall/ Masonry/ Concrete wall	100	10	Both sides	40 x 16	140 mm PROMASTOP® - COLLAR	140mm Ø PP with 3.5-8.0mm wall thickness	120*	120*
				40 x 18	160 mm PROMASTOP® - COLLAR	160mm Ø PP with 4.0-14.5mm wall thickness		
				30 x 4	32 mm PROMASTOP® - COLLAR	32 mm Ø PE with 2.9mm wall thickness		
					40 mm PROMASTOP® - COLLAR	40 mm Ø PE with 2.9mm wall thickness		
					50 mm PROMASTOP® - COLLAR	50 mm Ø PE with 2.9mm wall thickness		
				30 x 6	55 mm PROMASTOP® - COLLAR	55mm Ø PE with 2.9-4.4mm wall thickness		
					63 mm PROMASTOP® - COLLAR	63mm Ø PE with 2.9-4.4mm wall thickness		
				30 x 8	75 mm PROMASTOP® - COLLAR	75mm Ø PE with 2.8-6.7mm wall thickness		
					82 mm PROMASTOP® - COLLAR	82mm Ø PE with 2.8-6.7mm wall thickness		
				30 x 10	90 mm PROMASTOP® - COLLAR	90mm Ø PE with 2.7-10mm wall thickness		
					100 mm PROMASTOP® - COLLAR	100mm Ø PE with 2.7-10mm wall thickness		
					110 mm PROMASTOP® - COLLAR	110mm Ø PE with 2.7-10mm wall thickness		
				40 x 12	125 mm PROMASTOP® - COLLAR	125mm Ø PE with 3.1mm wall thickness		
				40 x 16	140 mm PROMASTOP® - COLLAR	140mm Ø PE with 3.9-5.8mm wall thickness		
				40 x 18	160 mm PROMASTOP® - COLLAR	160mm Ø PE with 4.9-9.5mm wall thickness		
Masonry/ Concrete wall				30 x 10	110 mm PROMASTOP® - COLLAR	110mm Ø PP with 2.7mm wall thickness	120~	120~
				40 x 18	160 mm PROMASTOP® - COLLAR	160mm Ø PP with 4.0mm wall thickness		
				40 x 24	250 mm PROMASTOP® - COLLAR	250mm Ø PP with 6.2mm wall thickness	120*	120*

* Uncapped/Capped (U/C)
 ~Uncapped/Uncapped (U/U)



Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-01049-CPR
 Page 6/8
 Date of Issue 2017-07-26

Substrate	Minimum Substrate Thickness (mm)	Annular space sealed with PROMASEAL® Acrylic Sealant (mm)	Collar Position	Inlay W X H (mm)	Reference	Pipe	Fire Resistance (mins.)	
							E	EI
Concrete floor	150	10 (to top face of floor)	Soffit	30 x 4	32 mm PROMASTOP®-COLLAR	32 mm Ø PVC with 1.8mm wall thickness	240*	240*
					40 mm PROMASTOP®-COLLAR	40 mm Ø PVC with 1.8mm wall thickness		
					50 mm PROMASTOP®-COLLAR	50 mm Ø PVC with 1.8mm wall thickness		
				30 x 6	55 mm PROMASTOP®-COLLAR	55mm Ø PVC with 2.3-3mm wall thickness		
					63 mm PROMASTOP®-COLLAR	63mm Ø PVC with 2.3-3mm wall thickness		
				30 x 8	75 mm PROMASTOP®-COLLAR	75mm Ø PVC with 3.1-4.8mm wall thickness		
					82 mm PROMASTOP®-COLLAR	82mm Ø PVC with 3.1-4.8mm wall thickness		
				30 x 10	90 mm PROMASTOP®-COLLAR	90mm Ø PVC with 4.2-7.4mm wall thickness		
					100 mm PROMASTOP®-COLLAR	100mm Ø PVC with 4.2-7.4mm wall thickness		
					110 mm PROMASTOP®-COLLAR	110mm Ø PVC with 4.2-7.4mm wall thickness		
				40 x 12	125 mm PROMASTOP®-COLLAR	125mm Ø PVC with 6.0mm wall thickness		
				40 x 16	140 mm PROMASTOP®-COLLAR	140mm Ø PVC with 6.1-7.5mm wall thickness		
				40 x 18	160 mm PROMASTOP®-COLLAR	160mm Ø PVC with 6.2-9.5mm wall thickness		
				30 x 4	32 mm PROMASTOP®-COLLAR	32 mm Ø PP with 2.9mm wall thickness		
					40 mm PROMASTOP®-COLLAR	40 mm Ø PP with 2.9mm wall thickness		
					50 mm PROMASTOP®-COLLAR	50 mm Ø PP with 2.9mm wall thickness		
				30 x 6	55 mm PROMASTOP®-COLLAR	55mm Ø PP with 2.9-4.4mm wall thickness		
					63 mm PROMASTOP®-COLLAR	63mm Ø PP with 2.9-4.4mm wall thickness		
				30 x 8	75 mm PROMASTOP®-COLLAR	75mm Ø PP with 2.8-6.7mm wall thickness		
					82 mm PROMASTOP®-COLLAR	82mm Ø PP with 2.8-6.7mm wall thickness		
				30 x 10	90 mm PROMASTOP®-COLLAR	90mm Ø PP with 2.7-10mm wall thickness		
					100 mm PROMASTOP®-COLLAR	100mm Ø PP with 2.7-10mm wall thickness		
					110 mm PROMASTOP®-COLLAR	110mm Ø PP with 2.7-10mm wall thickness		
				40 x 12	125 mm PROMASTOP®-COLLAR	125mm Ø PP with 3.1mm wall thickness		

* Uncapped/Capped (U/C)
 ~Uncapped/Uncapped (U/U)



Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-01049-CPR
 Page 7/8
 Date of Issue 2017-07-26

Substrate	Minimum Substrate Thickness (mm)	Annular space sealed with PROMASEAL® Acrylic Sealant (mm)	Collar Position	Inlay W X H (mm)	Reference	Pipe	Fire Resistance (mins.)	
							E	EI
Concrete floor	150	10 (to top face of floor)	Soffit	40 x 16	140 mm PROMASTOP®-COLLAR	140mm Ø PP with 3.5-8.0mm wall thickness	240*	240*
				40 x 18	160 mm PROMASTOP®-COLLAR	160mm Ø PP with 4.0-14.6mm wall thickness		
				30 x 4	32 mm PROMASTOP®-COLLAR	32 mm Ø PE with 2.9mm wall thickness		
					40 mm PROMASTOP®-COLLAR	40 mm Ø PE with 2.9mm wall thickness		
					50 mm PROMASTOP®-COLLAR	50 mm Ø PE with 2.9mm wall thickness		
				30 x 6	55 mm PROMASTOP®-COLLAR	55mm Ø PE with 2.9-4.4mm wall thickness		
					63 mm PROMASTOP®-COLLAR	63mm Ø PE with 2.9-4.4mm wall thickness		
				30 x 8	75 mm PROMASTOP®-COLLAR	75mm Ø PE with 2.8-6.7mm wall thickness		
					82 mm PROMASTOP®-COLLAR	82mm Ø PE with 2.8-6.7mm wall thickness		
				30 x 10	90 mm PROMASTOP®-COLLAR	90mm Ø PE with 2.7-10mm wall thickness		
					100 mm PROMASTOP®-COLLAR	100mm Ø PE with 2.7-10mm wall thickness		
					110 mm PROMASTOP®-COLLAR	110mm Ø PE with 2.7-10mm wall thickness		
		40 x 12	125 mm PROMASTOP®-COLLAR	125mm Ø PE with 3.1mm wall thickness				
		40 x 16	140 mm PROMASTOP®-COLLAR	140mm Ø PE with 3.9-5.8mm wall thickness				
		40 x 18	160 mm PROMASTOP®-COLLAR	160mm Ø PE with 4.9-9.5mm wall thickness				
		10 (to both faces)	Both faces	30 x 10	110 mm PROMASTOP®-COLLAR	110mm Ø PP with 2.7mm wall thickness	120~	120~
				40 x 16	160 mm PROMASTOP®-COLLAR	160mm Ø PP with 4.0mm wall thickness	120*	120*

* Uncapped/Capped (U/C)
 ~Uncapped/Uncapped (U/U)



Appendix UL-EU Certificate

Certification Mark	UL-EU mark
Certificate No.	UL-EU-01049-CPR
Page	8/8
Date of Issue	2017-07-26

The UL-EU Mark, as displayed below, shall appear on certified products only. Minimum size is not specified, as long as the Mark is legible. The following is suggested.



The minimum height of the registered trademark symbol ® shall be 1 mm. When the overall diameter of the UL-EU Mark is less than 9.5 mm, the trademark symbol may be omitted if it is not legible to the naked eye.

The UL-EU Mark may appear on a label, nameplate, or may be cast, stamped or molded into the product. When appearing on a label or nameplate, the Manufacturer's name or trademark along with a model number are also required on that same label or nameplate. If cast, stamped or molded, the Certificate Manufacturer's name or trademark and model number shall also appear elsewhere on the product.

All content shall be in accordance with the details provided on this UL-EU Certificate.

PROCUREMENT

The Production site may reproduce the Mark or obtain it from a UL authorized supplier. The list of UL authorized suppliers can be found on UL's online directory at www.ul.com.

