

Certificate of Product Approval

Certificate Number: 762c

Issue: 08

PROMAT RESEARCH AND TECHNOLOGY CENTRE NV

Bormstraat 24
2830 Tiselt
Belgium



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) as detailed below:

Products

Protective Covering Materials

CAFCO® C300
PROMASPRAY® P300

Standards

LPS 1107: Issue 1.2

Requirements, Tests and Methods of Assessment of Passive Fire Protection Systems for Structural Steelwork.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd.

Karen Coull

Certification Scheme Manager

31 July 2018

Date of Issue

18 February 2011

Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of BRE (the Building Research Establishment Ltd.)



Appendix to Certificate No: 762c PROMAT RESEARCH AND TECHNOLOGY CENTRE NV

Issue: 08

Product Name					LPCB Ref. No.
CAFCO®300 PROMASPRAY® P300					762c/01
Steel Section	Steel Section Factor range (Hp/A)	Applied Thickness Range (mm)	Critical Temperature Range (°C)	Fire Resistance Period (mins)	Appendix No.
I-section beams and H-section columns	30 - 320	12 – 72	350, 400, 450, 500, 550, 600, 620, 650, 700	30, 60, 90, 120, 180 & 240	1
Hollow section beams and columns	30 - 310	12 – 72	350, 400, 450, 500, 550, 600, 620, 650, 700	30, 60, 90, 120, 180 & 240	2

Notes:

- LPCB Ref 726c/01 – approval for Cafco®300 and PROMASPRAY® P300 without accelerator, profile application applied in several coats dependant on thickness.
- The thicknesses given for open H- and I-sections also apply to steel sections of other shapes, e.g. U-, L- and T-sections under consideration of the same section factor value.
- Approved Manufacturers
The following Companies manufacture the product listed on this certificate.
These Companies are audited by the LPCB to ensure the product certification requirements are met.

Promat Fire Protection LLC (C762c)
Plot No.597-921,
Dubai Investment Park 2,
PO Box 123945,
Dubai,
UAE

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd..

Karen Coull
Certification Scheme Manager

31 July 2018
Date of Issue

18 February 2011
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of BRE (the Building Research Establishment Ltd.)


